

EngA[®]

ENGINEERED AIR[®]

**INSTALLATION, OPERATION
AND MAINTENANCE MANUAL**

FOR

G-TRAC

Model 1.1

INDIRECT FIRED HEATING CONTROLLER



UNIT MODEL NO.

UNIT SERIAL NO.

SERVICED BY: _____

TEL. NO: _____

**CANADIAN
HEAD OFFICE
AND FACTORY**

1401 HASTINGS CRES. SE
CALGARY, ALBERTA
T2G 4C8
Ph: (403) 287-4774
Fx: 888-364-2727

**USA
HEAD OFFICE
AND FACTORY**

32050 W. 83rd STREET
DESOTO, KANSAS
66018
Ph: (913) 583-3181
Fx: (913) 583-1406

**CANADIAN
EASTERN FACTORY**

1175 TWINNEY DRIVE
NEWMARKET, ONTARIO
L3Y 5V7
Ph: (905) 898-1114
Fx: (905) 898-7244

SALES OFFICES ACROSS CANADA AND USA

Retain instructions with unit and maintain in a legible condition.
Please give model number and serial number when contacting
factory for information and/or parts.

www.engineeredair.com

TABLE OF CONTENTS

I.	PURPOSE	1
II.	CAUTION	1
III.	SIMPLIFIED OPERATION	1
IV.	TEMPERATURE CONTROL.....	2
	<i>G-TRAC as a Slave to the CTRAC</i>	<i>2</i>
	<i>Suggested Settings Re Hunting Problems.....</i>	<i>2</i>
	<i>G-TRAC as a "Stand Alone Device"</i>	<i>2</i>
V.	MASTER SET-POINT	3
	<i>TE 6100 Wiring Connections and Resistance Values</i>	<i>3</i>
	<i>Sensor Resistance Chart for TE 6100-960 and TE 6000-960.....</i>	<i>4</i>
	<i>Temperature Can Be Controlled By</i>	<i>4</i>
VI.	RESET CONTROL	4
	<i>Example 1</i>	<i>5</i>
	<i>Example 2</i>	<i>5</i>
	<i>Example 3</i>	<i>5</i>
	<i>Multiple Room Sensors</i>	<i>6</i>
	<i>Room Reset Authority Pot.....</i>	<i>6</i>
VII.	TO TEMPORARILY DRIVE THE UNIT TO HIGH OR LOW FIRE.....	6
VIII.	G-TRAC DISCHARGE TEMPERATURE SENSOR/SETPOINT CALIBRATION.....	6
	<i>Method 1</i>	<i>6</i>
	<i>Method 2</i>	<i>7</i>
IX.	ROOM RESET CONTROL CALIBRATION	7
	<i>Method 1 (Most accurate method).....</i>	<i>7</i>
	<i>Method 2 (Does not correct for remote wire resistance).....</i>	<i>7</i>

	<i>Method 3</i>	8
	<i>Method 4 (May correct minor electrical noise on remote wire)</i>	8
X.	BMS RESET OF THE DISCHARGE AIR TEMPERATURE	8
XI.	POTENTIOMETERS ON THE G-TRAC	10
XII.	DIAGNOSTIC LIGHTS	10
	<i>Heat Call Light</i>	10
	<i>Pre-Purge Timer Light</i>	11
	<i>Burner Enabled Light</i>	11
XIII.	TROUBLE SHOOTING	11
	<i>Supply Blower Not Starting</i>	11
	<i>No Heat (Burner Not Firing)</i>	12
	<i>Low Heat (Burner Firing)</i>	12
	<i>Unit Short of Temperature Rise</i>	12
	<i>Over Delivering Air</i>	13
	<i>Inlet Gas Pressure Low or Burner Rumbles</i>	13
	<i>Regulator/Manifold Pressure Low or Slow to Respond</i>	13
	<i>Gas Valve Won't Open Fully (G-TRAC Slave to CTRAC)</i>	13
	<i>Water and Ice From Combustion</i>	13
	<i>Over Heating</i>	14
	<i>Rapid Cycling of SA Contacts on G-TRAC Connected to BMS Reset</i>	14
	<i>G-TRAC not responding to BMS signal</i>	14
	<i>Flame Failure Lockouts</i>	14
	"B" and "C" BURNER ELECTRODE DETAIL	15
XIV.	CHANGING A G-TRAC IN THE FIELD	15
	<i>TO SET PRE-PURGE TIME DELAY</i>	15
	<i>TO SET THE MAINTAIN PURGE TIME DELAY</i>	16

<i>ESTIMATED POT SETTINGS (Use for situations where design values not available)</i>	16
Combustion Set Up	17
High Fire Combustion Set Up	17
Low Fire Combustion Set Up	17
Mid-Fire Range Combustion Set Up	17
CHECK OUT FOR G-TRAC-1 NORMAL OPERATION	18



G-TRAC CONTROL FOR MODULATING DG UNITS

If you note any errors, omissions, or items that require further clarification, please contact Wade Pascoe at (403) 287-4775 or Fax (403) 287-4799 or (403) 243-5059.

To ensure warranty is honoured, only a qualified HVAC service person or gas fitter that has received training on the G-TRAC, should be employed for service and troubleshooting. If information is required please contact the nearest Engineered Air office.

If conversion of degrees F to C is wanted, refer to table on page 4.

I. PURPOSE

The **G-TRAC** is designed to provide an accurate method of temperature control by modulating the size of the flame on the DG Series heaters. It has been designed to operate with a variety of discharge control devices and has the ability to utilize a room sensor for set point override control. The usual controls being applied to the **G-TRAC** are arranged to Johnson Controls TE 6000/TE 6100 series or the **G-TRAC** is being operated as a slave to the CTRAC. It is often applied to Gordon Piatt or Maxon Burner Systems.

II. CAUTION

The **G-TRAC** has a number of internal potentiometers. These are set up at the factory. These potentiometers should not be field adjusted unless consultation has been made with someone who is familiar with the control. Tampering may misalign the control operation resulting in poor combustion and/or poor temperature control or calibration.

III. SIMPLIFIED OPERATION

- 24 V power to terminals "H" and "N"
- 36 seconds later terminals "SA" and "SA" make to start supply fan if the heat switch is not "on".

NOTE: *If the heat switch is already "on" there may be a further delay before the supply blower starts while the heat starts.*

- Closing the remote heat switch places 24 V power to "HS" (*heat switch*).
- If there is a call for heat from the temperature control device attached to the G-TRAC:
 - As a safety procedure, the G-TRAC checks if "AS" is closed before the combustion blower starts. If it is, then "CB" contacts will not close to start the combustion blower due to a closed air switch.
 - If "AS" is open then "CB" to "CB" will close to start the combustion burner motor. Pre-purge is factory set between 1 and 8 minutes. The length of pre-purge time is determined by the size of the heat exchanger. (*Jumper selection listed in Section XIV about replacing the G-TRAC.*)
 - The combustion blower moves air into the combustion chamber and the airflow closes the air switch putting 24 volts on G-TRAC terminal "AS" (*air switch*).
 - After pre-purge is complete "FR" to "FR" (*flame relay*) closes to power the flame relay for an ignition attempt.
 - If the supply blower had been shut off, "SA" to "SA" will close again 36 seconds after the pre-purge is done to re-start the supply air fan. This is to allow for heat exchanger warm-up.

- The flame relay (*external to the G-TRAC*) energizes the ignition transformer and pilot solenoid valve.
- When the pilot is established, the flame relay will power the main gas valve and shut off the spark.
- The G-TRAC and its associated controls maintain the discharge air temperature.

If the rise in discharge air temperature at low fire is greater than that required to satisfy the set-point, it is necessary to cycle the burner on and off. The normal G-TRAC will likely cycle at about one minute intervals and at a 20°F-temperature swing when a low temperature rise is required. At extra cost the G-TRAC can be tuned to "high sensitivity" which causes more burner cycling but gives better discharge control during conditions when only a small increase is needed in discharge temperatures.

When higher temperature rise is required the G-TRAC will modulate the size of the flame rather than cycle the burner. Note that burner cycling may occur in temperatures where theory suggests modulation should be possible. This is caused by the mass of the heat exchanger, the time heat transfers to the air and the time for the discharge temperature control device to react.

- After a heat call is complete the combustion blower will remain in a "maintain purge" mode for 7 to 15 minutes (*depending on jumper selection noted later*). If the combustion blower is running it will allow a heat call to start immediately without going through pre-purge.

IV. TEMPERATURE CONTROL

G-TRAC as a Slave to the CTRAC

In this application there is no temperature control sensor or set point attached to the G-TRAC. The G-TRAC's ability to control the firing rate is done with a 0 to 10 VDC volt signal from a CTRAC2.1 terminals "HD and B", (*0 to 8.5 VDC on the CTRAC2 version terminal "HT and B"*). The CTRAC2.1 is the master control of the system. G-TRAC heat call light will be activated when about a 4.5 VDC signal is received from the CTRAC. Terminal HT to B are connected to D and W of G-TRAC. Refer to C-TRAC manual also.

Suggested Settings Re Hunting Problems

C-TRAC2.1 with G-TRAC with TE 6000-960 discharge sensor – may modulate through 20 degrees.

Set C-TRAC Pots	Set G-TRAC Pots
P3 = 6 min. as high as 9	P5 = 2
P6 = 5 ***	P6 = 4
P11 = 2	P8 = 4

C-TRAC2.1 with G-TRAC and hyper sensor – may modulate through 10 degrees.

Set C-TRAC Pots	Set G-TRAC Pots
P3 = 6 min. as high as 9	P5 = 2
P6 = 5 ***	P6 = 4
P11 = 2	P8 = 4

*** On C-TRAC2.1 pot 6 does not exist.

G-TRAC as a "Stand Alone Device"

Either the internal set point or an external set point will be used as the discharge set point. Most installations will use an external set point.


The usual discharge set-point control is a Penn TE 6100-960 control (*which is both a set point and sensor, but only the set point half is wired*). The TE 6100-960 set-point device requires a cover such as T4000-264S. The discharge sensor is a Penn TE 6000-960 sensor located in the discharge air stream.

V. MASTER SET-POINT

TE 6100 Wiring Connections and Resistance Values

As a SET POINT, the G-TRAC is designed to use either:

- The set point pot 4 (*auxillary setpoint*) (*range of 12-35°C or 55-95°F*). If the G-TRAC pot 4 auxillary set-point is used, terminals “SP and S” must be jumped, or;
- The Johnson TE 6100-960 set point (*range of 50-85°F and often remote mounted*). If the TE 6100-960 is used as a set-point, “S to SP” must not be jumpered and the TE 6100 must be wired:



TE6100-960 Sensor/Set Point			
SENSOR	<i>(purple and blue)</i>	Same resistance as TE 6000-960	
		Set-Point Dialed To	
		60 degrees	90 degrees
POT	<i>(orange and grey)</i>	2.725 K Ω	3.272 K Ω
	<i>(orange and blue)</i>	3.184 K Ω	2.702 K Ω
	<i>(blue and grey) 970 Ω</i>		
OTHER	<i>(purple and orange)</i>	4.19 K Ω	3.71 K Ω
	<i>(purple and grey)</i>	About 1.981 K Ω (<i>varies with element temp.</i>)	

TE 6000 SENSOR		
SENSOR	<i>(purple and blue)</i>	Resistance in table below

Sensor Resistance Chart for TE 6100-960 and TE 6000-960

°C	°F	Resistance Ω	°C	°F	Resistance Ω	°C	°F	Resistance Ω
-40	-40	602-605	18.3	65	983	48.9	120	1234
-34.4	-30	633	20	68	996	54.4	130	1269
-28.9	-20	665	20.6	69	1000.7	60	140	1333
-23.3	-10	698	21.1	70	1005	65.5	150	1365
-17.8	0	732	23.9	75	1026.5	71.1	160	1437
-12.2	10	768	26.7	80	1048	76.7	170	1491
-8.7	20	804	29.4	85	1070	82.2	180	1546
-1.1	30	842	32.2	90	1092	87.7	190	1602
4.4	40	881	35.6	95	1116	93.3	200	1659
10	50	921	37.8	100	1139	98.8	210	1718
12.8	55	941.5	43.3	110	1186	100	212	1778

Reference resistance is 1035 ohms at 77°F. Resistance tolerances are ±0.05 to 0.15% at 77°F. Temperature range +32 to +104°F. (TE 6100-960 pot is 53C3, 500R, 7/8 by ¼ shaft.)

NOTE: Engineered Air's design discharge temperature range is 30 to 140°F.

Temperature Can Be Controlled By

DISCHARGE AIR CONTROL

Consists of TE6000-960 duct sensor and set point (*often TE 6000-960*) wired as above (*or use the internal set point pot 4 with a jumper on "S to SP"*).

DISCHARGE CONTROL WITH ROOM RESET

Consists of duct sensor and set point wiring as noted above with room sensor/set-point also connected to the G-TRAC. (*To activate this feature there must be a jumper from terminals "RR and +".*)

Seldom used is control from a Honeywell T991A or equivalent control wired to terminals "D, U, M and V" (*R=D, W=U, B=M and V*).

NOTE: To determine your system, refer to the unit wiring diagrams.

VI. RESET CONTROL

TE 6100 WIRE COLOUR	C-TRAC2.1 TERMINAL	PURPOSE
Room reset sensor/set-point		
Blue	_____ Z	Room reset set point +
Grey	_____ V	Room reset set point □
Orange	_____ Y	Room reset centre tap
Violet	_____ X	Room sensor

In a stand-alone system the G-TRAC operates as a discharge air control. If a room-reset control is used, the room set point and sensor will modify the set point. This is best explained by an example. The room reset ratio authority (*pot 2*) setting determines high and low discharge points.

Example 1

Discharge	Room	Room Reset	High Discharge	Low Discharge
Set point	Set-point	Ratio (<i>Pot 2</i>)	Room Call Max	Room Call Min
70°F	72°F	Pos 3 = ±14	84°F	56°F

As the room temperature deviates from 72°F it can modify the discharge temperatures up to as high as 84°F and as low as 56°F.

Example 2

Discharge	Room	Room Reset	High Discharge	Low Discharge
Set point	Set-point	Ratio (<i>pot 2</i>)	Room Call Max	Room Call Min
55°F	72°F	Pos 3 = ± 14	69°F	41°F


As the room temperature deviates from 72°F it can modify the discharge temperature up to as high as 69°F and as low as 41°F. Note you cannot reach a 72° room temperature. Also note that the internal design of the *G-TRAC* will resist dropping the discharge temperature below 52°F.

Example 3

Discharge	Room	Room Reset	High Discharge	Low Discharge
Set point	Set-point	Ratio (<i>pot 2</i>)	Room Call Max	Room Call Min
63°F	72°F	Pos 4 ± 18	81°F	45°F


This will allow discharge temperature as high as 81°F. If the room set point were turned up to 76°F we would reset discharge to 81°F until the space temperature was raised to about 76°F. Also note that the internal design of the *G-TRAC* will resist dropping the discharge temperature below 52°F.

NOTE: When dealing with systems that are equipped with room reset controls be aware that any room sensor must be located in an area where it is sensing a true average space temperature. A room reset that is located in a hot or cool area that does not represent the room temperature will create room comfort problems. Also do not locate the reset sensor in an area that is affected by discharge air from any duct or other device. The *G-TRAC* terminals "RR and +" need to be jumped when the room reset is used. Note that on some wiring diagrams this may be jumped during one mode and inactive in another.



Multiple Room Sensors

Four sensors can be wired to give an average reading of room temperatures to the Trac control. They must be wired in a series/parallel arrangement. The drawing shows a circuit making use of the built in sensor in the T#6100 Johnson Sensor/set point assembly and using TE6000 sensors for the other three. (The other three could also be TE6100, just using the sensor wires)



Room Reset Authority Pot

<u>Position</u>	<u>Reset Amount</u>	<u>Position</u>	<u>Reset Amount</u>
1	±9°F	4	±18°F
2	±11°F	4.5	±23°F
3	±14°F	5	±32°F

VII. TO TEMPORARILY DRIVE THE UNIT TO HIGH OR LOW FIRE

To force a G-TRAC to full heat, short the discharge sensor "Q" and "U".

To force a G-TRAC to low fire substitute a 1000 ohm resistor for the discharge sensor and adjust the set-point pot to a point that just turns the heat call light on.

VIII. G-TRAC DISCHARGE TEMPERATURE SENSOR/SETPOINT CALIBRATION

Calibration is best done with supply fan on.

Method 1

Bring the G-TRAC to a stable discharge temperature by the following steps after disconnecting any override devices. If the room reset option is wired on the unit you are working on you must disconnect the jumper between "RR and +". Note that all other potentiometer settings should be finalized before continuing with this procedure. Calibration may be affected if other pots are adjusted after this procedure is complete.

- Jumper the combustion blower.
- Jumper the flame relay terminals.
- Place a Q209 Honeywell 140 ohm pot on the V9055 valve to modulate it to a fixed position and allow it to run until discharge air temperature is stable in the modulated area of the valve stroke and between 55 to 90°F.
- Place a thermometer within one inch of the discharge sensor.
- Set the TE 6100-960 set-point dial (*or internal set point if used*) to match the reading on the thermometer.
- Adjust the G-TRAC calibration pot P1 until the heat call light just goes out.

Method 2

This description assumes the control is operating as an internal set-point control. (*SP and P are jumped.*) This method does not correct for remote wire resistance.

- Disconnect any external override controls (*if room override option is used remove the "RR and +" jumper to disable it.*)
- Set all pots to their required positions (*except P1 and P3*).
- Allow the G-TRAC to run until it completes its pre-purge.
- Set pot 4 to 70°F (21°C) (*auxiliary set point*).
- Connect a 1005-ohm resistor in place of the discharge sensor. A resistor of this value represents a 70°-discharge temperature. It should be wired to terminals "Q and U".
- Adjust pot 1 until the heat light just shuts off. This places the G-TRAC in its dead band area.
- Return the control to normal.

Assuming the control is operating with an external set point. Follow the above instructions except set the remote TE 6100-960 sensor to 70°F (21°C).

If there is concern about doing this calibration in cool weather and drawing cold air into the building, disconnect the wires to "FR and SA" to shut off the heat and supply air fan while the calibration is done.

IX. ROOM RESET CONTROL CALIBRATION

Method 1 (*Most accurate method*)

- Remove the jumper between "RR and +".
- Remove the wires connected to "Z and X" and measure the resistance on them. Reconnect the wires to "Z and X".
- Compare the resistance to that shown on the TE 6000 Sensor chart located in this manual.
- Adjust the reset set point to the same value found in the above step.
- Measure the voltage across "RR and +" and adjust pot 3 until the meter just reads a zero value (*or in absence of a meter, a less accurate method is to jumper "RR" and "+" and adjust pot 3 until the heat call light just goes off*).
- Reconnect wiring to "RR and +".

Method 2 (*Does not correct for remote wire resistance*)

- Disconnect all room reset control terminals "V, X, Y and Z" from the G-TRAC. Connect a jumper across the G-TRAC terminals "RR and +".

- Place a 1005-ohm resistor across G-TRAC terminals "X and Z" to simulate 70°F (21°C).
- Connect the TE 6100-960 set-point to the G-TRAC terminals as follows:
 1. BLUE to G-TRAC terminal Z
 2. ORANGE to G-TRAC terminal Y
 3. GREY to G-TRAC terminal V
- Turn the TE 6100-960 dial to 70°.
- Adjust pot 3 until the heat light just shuts off

Method 3

- Disconnect jumper from "RR and +".
- Set the discharge air calibration using a 1005-ohm resistor (*to simulate 70°F*) in place of the discharge sensor. Adjust set point just short of where the heat call light comes on.
- Accurately measure the room temperature next to the room sensor.
- Set the room set point to the same temperature as was measured.
- Ensure the jumper is re-installed "RR" to "+".
- Adjust pot 3 until the heat call light is just short of coming on.

Method 4 (*May correct minor electrical noise on remote wire*)

- Disconnect wires to terminals "Z and X" and measure the resistance on them. Reconnect the wires.
- Compare the reading with the TE 6000 resistance chart in this document.
- Adjust the room reset set-point dial to the same value as related to the chart. (*Also ensure "RR and +" are jumpered.*)
- Adjust pot 3 until the Heat Call light just comes on.

X. BMS RESET OF THE DISCHARGE AIR TEMPERATURE

The G-TRAC has the ability to accept an input from a BMS 0-10 VDC or 4-20 ma signal on the G-TRAC terminals "+ and -". This is not optically isolated. Pot "P7" sets the amount of override that the BMS signal will be allowed when the BMS signal is at its highest. Setting 1 is about $\pm 32^\circ\text{F}$ and setting 5 is about $\pm 60^\circ\text{F}$. The amount of reset authority may be slightly higher when using a 0 to 10 VDC reset signal from the BMS. (*Setting 1 = $\pm 40^\circ\text{F}$; setting 5 = $\pm 75^\circ\text{F}$.*)

Pot 7 Setting	Reset Value With 0-10 VDC Signal	4-20 ma Signal
5	+ 75°F	+ 60°F
4	+ 68°F	+ 54°F
3	+ 60°F	+ 48°F
2	+ 50°F	+ 40°F
1	+ 40°F	+ 32°F

Reset from the BMS signal will not be truly lineal. It will start to reset about 3 VDC. The reset will begin to ramp gently at 3 volts and ramp more steeply as the reset voltage is increased.

Approximate relationship between 0-10 VDC and 4-20 ma signal.

<u>VDC</u>	<u>ma</u>	
0	0	Note: zero reset less than 2 VDC or less than 1 ma
2	3	
4	8	
5	10	
6	12	
8	16	
10	20	

There is a possibility of a grounded BMS signal that is not fully recognized by the G-TRAC. This occurs when the BMS control signal's negative wire and the G-TRAC's 24 volt power supply both have a grounded negative or common terminal. These are directly grounded, grounded through a transformer, or another point. If the grounds are located at different places, it is possible to have different ground potentials or voltages. This often shows up as a situation where the BMS signal is 10 VDC when not connected to the G-TRAC but falls off to a much lower value when connected to the G-TRAC. The BMS signal may even fall low enough to drive the calculated set point below the controls setting. It can also result in "SA-SA" contacts cycling and damage the supply air motor or contactor.


If this is a problem:

1. Disconnect all grounds on the G-TRAC power supply transformer. Check the operation of the system.
2. If instructions above did not resolve the problem remove ground from the power supply transformer for the V9055 gas valve controller.
3. Ensure the electrician properly grounded the unit to the building ground. Failure to do so may create floating ground problems.
4. If there's still a problem when these ground wires are removed, test operation of the G-TRAC with a fully isolated power supply or use a 9 VDC battery to G-TRAC + and □ terminals. If this method will drive it, the G-TRAC is OK. (*A new 9 V battery will drive a G-TRAC for a few minutes.*)
5. Ensure grounds from different control transformers are not mixed up.

NOTE: Field analog control inputs require signal isolation to prevent ground loop signal corruption and/or damage to the controller(s).

XI. POTENTIOMETERS ON THE G-TRAC

<p>P1 DISCHARGE CALIBRATION – Factory set as required. Do not readjust without insuring that no reset signals are affecting discharge temperature (Page 7).</p>
<p>P2 ROOM RESET RATIO – This sets the amount of authority the room reset will have on the set-points desired discharge. 1=MIN RESET ±9° 5=MAX RESET ±32°</p>
<p>P3 ROOM CALIBRATION – Adjust as required if a room sensor is in use. Ensure the discharge sensor is not affecting the signal (Page 8).</p>
<p>P4 AUXILIARY SET POINT – This pot is not normally used. If it is in use there will be a jumper across "SP and S" or "SP and Y"</p>
<p>P5 VALVE SENSITIVITY – This adjusts the strength of the signal to the valve. As it is set to a lower number, signal strength is higher and the valve opens further. If this is not set to a low enough number (about 3) there may not be enough drive to open the mod valve fully. If control is from a CTRAC2.1 and valve cannot open fully, set lower until it does.</p>
<p>P6 INTERNAL CONTROL BAND – This pot selects a point above and below set point that a modification is made to the valve output signal, which causes it to react quicker. The amount of modification is not adjustable 1=10°/5=3°. Usual setting is 3, but when G-TRAC is controlled by CTRAC set at 4.</p>
<p>P7 BMS RESET RATIO – Used on building management systems only. Position 5 = +60, 1 = +32 on 4-20 MA BMS System Position 5 = +75, 1 = +40 on 0-10 VDC BMS System</p>
<p>P8 BURNER ON/OFF CONTROL BAND – This sets the points at which the burner cycles on and off. There is no delay off. Setting this control low increases cycling. When control is from a CTRAC, usual setting is "4", setting 1 = 2°F deadband, setting 5 = 6°F.</p>



- To force the unit to High fire, short the discharge sensor "Q" and "U".
- To force the unit to Low fire, substitute a 1000-ohm resistor for the discharge sensor and adjust the set-point pot to just turn the heat call light on.

Regarding the above pot settings, note the following:

- Pot 5** Do not set higher than 2.5 or 3 as there may not be enough power to drive the modulating gas valve fully open. This pot regulates the response of the valve to the G-TRAC voltage signal. Three (3) is the normal set point. Too low a set point may result in hunting due valve movement being too great for the amount of signal change at the internal G-TRAC amplifier. This will result in unstable discharge temperatures due to excessive hunting.
- Pot 6** Operates in conjunction with pot P5. Normal set point is 3 and the set point when the G-TRAC is controlled by a CTRAC is 4. Setting this pot too high can result in hunting.

XII. DIAGNOSTIC LIGHTS

To simplify troubleshooting and to see what the unit is doing at the moment, there are a number of "LED" lights.

Heat Call Light

Indicates that the discharge sensor and/or any of the reset devices wired to the G-TRAC are calling for more heat.

Pre-Purge Timer Light

The pre-purge timer light will activate when there is a call for heat and the burner is in the pre-purge mode. The combustion blower should be running but there should be no flame. When this light goes out, if the heat call is still present, the burner-enabled light will come on. Note that pre-purge time is pre-set at the factory. The higher the burner turn down and the larger the heat exchanger, the longer the pre-purge. Pre-purge time is set by cutting jumpers as noted in Section XIV about field replacement of the control.

Burner Enabled Light

Pre-purge time is complete. The burner should be firing and will maintain discharge temperature as per the control system wired to the G-TRAC.

XIII. TROUBLE SHOOTING

Supply Blower Not Starting

G-TRAC DIAGNOSTIC LIGHTS				
HEAT CALL	PRE-PURGE TIMER	BURNER ENABLE	COMBUSTION BLOWER	OPERATING CONDITIONS OR PROBLEM DIAGNOSIS
OFF	OFF	OFF	OFF	Check for 24 VAC on terminals "H and N". Allow 45 seconds for fan start up.
ON	OFF	OFF	OFF	Check for shorted combustion air switch.
ON	ON	OFF	OFF	Check combustion blower motor circuit ***
ON	ON	OFF	RUNNING	Normal for morning start up. Supply fan is held off by pre-purge cycle xxx
ON	OFF	OFF	ON	No power to A/S terminal. Check for open A/S or failed combustion fan.
OFF	OFF	OFF	ON	Pre-purge complete. No heat call, S/A fan will start in 36 seconds.
ON	OFF	ON	ON	Blower will start in 36 seconds.

*** This condition is unlikely to occur. If the combustion blower stops, The air switch (AS) will open circuit and the pre-purge light will go off.

xxx If this is the first start and the discharge air sensor is warm but the O/A is cool, then the supply fan may not start for 36 seconds or it may cycle.

No Heat (Burner Not Firing)

G-TRAC DIAGNOSTIC LIGHTS				
HEAT CALL	PRE-PURGE TIMER	BURNER ENABLED	COMBUSTION BLOWER	OPERATING CONDITIONS OR PROBLEM DIAGNOSIS
OFF	OFF	OFF	OFF	No heat call. Check if "HS" is powered. Check discharge and/or reset sensors and set points.
ON	OFF	OFF	OFF	Shorted combustion air switch or faulty combustion fan motor.
ON	OFF	OFF	RUNNING	Is there power on terminal "AS"? If not, is air switch open?
ON	ON	OFF	RUNNING	Unit running in pre-purge, which lasts 1 to 8 minutes. If pre-purge light stays on, G-TRAC may be faulty.
ON	OFF	ON	RUNNING	Check for flame failure and/or power to flame relay. G-TRAC thinks all is operating okay and heat is on.
OFF	OFF	OFF	RUNNING	No heat call. G-TRAC has finished firing and is in "maintain purge" mode for 1 to 15 minutes. If it stays like this, check sensors, set points, resets, and calibration.
OFF	ON	OFF	RUNNING	There has been a short heat call. Check for intermittent wiring, electrical noise, intermittent sensors, set points, or rapidly changing BMS Signals. ***

*** Shielded wire should be used on all sensors and remote thermostats.

Low Heat (Burner Firing)

G-TRAC DIAGNOSTIC LIGHTS				
HEAT CALL	PRE-PURGE TIMER	BURNER ENABLED	COMBUSTION BLOWER	OPERATING CONDITIONS OR PROBLEM DIAGNOSIS
EITHER	OFF	EITHER	RUNNING	Check discharge and/or reset sensors and set-point calibration.
ON	ON	OFF	RUNNING	Unit is on pre-purge. If unit does not start within 1 to 8 minutes, the G-TRAC may be faulty.
ON	OFF	ON	RUNNING	Is unit over delivering supply air or is inlet gas pressure low? ***

*** Inlet gas pressure should not fall to less than 6" on a 7" system or less than 13" on a 14" system when the unit is at high fire.

NOTE: The following are some possibilities that are associated with lack of heat output from G-TRAC's.

Unit Short of Temperature Rise


If inlet gas pressure, manifold gas pressure and combustion are correct, note below, "Over Delivering Air".

Over Delivering Air

At the time of installation and air balancing, the unit is often set-up in warmer weather than the design temperature rise. If the air balancer did not allow for the changes that will occur in air volume in cold weather then the unit will appear to be short of temperature rise. As the fan is a constant volume device and as it is located before the heat exchanger, air will expand as it is heated. The amount of change will be about 20% increase in air volume from minus 30° F to 70° F. Therefore to give a rough sample, assuming a 10,000 CFM 100% fresh air unit (*located in an area that reaches -30° F in the winter*) was being air balanced on a 75°F day with the heat off. The unit design temperature rise is 100°F. It should be balanced to deliver about 8,200 CFM. On a day that is -30°, the fan is still delivering 8,200 CFM onto the heat exchanger, but as the air expands over the exchanger there is 10,000 CFM coming off of the unit. Temperature rise should meet the 100° design to give a discharge temperature of 70°. (*If the unit had been balanced to deliver 10,000 CFM on the 75° day, then on the -30° day noted above, the temperature rise would only be about 80° to give a final discharge temperature of about 50° at about 11,800 CFM.*)

Inlet Gas Pressure Low or Burner Rumbles

DG burners must have adequate inlet gas pressure. The temperature rise will be affected if gas pressure falls below 6.5 inches on units designed for 7-inch inlet pressure. On units designed for 14-inch gas pressure inlet pressure cannot fall below 12-inches. These pressures must be measured at high fire conditions. Burner manifold pressure must be measured on tap for Gordon Piatt Burners.



On some indoor units the vent orifice fitting on the RV appliance regulator is to be vented to atmosphere. The field installed vent line should be sized adequately especially on longer runs. If there is more than one regulator connected to a common run that includes the main regulator, and the line is not adequately sized, an erratic inlet pressure will result and cause improper combustion and also burner pulsating problems.

Some SJ unit manifolds have RV appliance regulators with a vent limiting orifice (usually a brass orifice marked "12A06"). Ensure that this tiny orifice is free of dirt or debris. A plugged orifice will impede a regulators opening flow and cause improper air/fuel mixtures.

Regulator/Manifold Pressure Low or Slow to Respond

If the orifice or tube in the top of the regulator is plugged, this may stop regulator from responding.

Gas Valve Won't Open Fully (G-TRAC Slave to CTRAC)

This problem seldom occurs at initial daily start-up. It is usually triggered by some unknown sequence of events. At first the system operates normally, then suddenly (*usually after leaving a heat call on the CTRAC and then re-establishing the heat call*) the G-TRAC does not respond normally to the incoming voltage from the CTRAC. If there is a full call for heat from the CTRAC heat output ramp but the G-TRAC does not fully open the modulating valve:

- Ensure sensors are in shielded wire.
- Isolate CTRAC and G-TRAC 24 VAC power supplies.
- If that does not resolve the problem decrease the setting on the G-TRAC pot 5 from 3 to a lower value. Usually setting it to 2 is enough though occasionally you must set pot 5 as low as 1.

Water and Ice From Combustion

These heat exchangers are very efficient. Water is one of the major products of combustion and as such must be controlled. The units are equipped with a drain. It is however best to allow water to leave the unit in the flue gases in vapor form. Combustion that is set at maximum efficiency will produce excess moisture. Often it is desirable to have 1% to 2% higher excess oxygen readings than those normally listed to assist in keeping the flue gases drier. Also note that extended chimneys can contribute to condensation problems (*especially if they are not insulated or at least double walled*). Water in the heat exchanger can lead to premature failure due to thermal stress or freezing. Another source of excess condensation is when a unit designed with capacity to

heat 100% outside air is operating with very little outside air, therefore operating at a low fire or cycling. This allows the cool flue gases from low fire to cool and condense in the chimney.

Over Heating

G-TRAC DIAGNOSTIC LIGHTS				
HEAT CALL	PRE-PURGE TIMER	BURNER ENABLED	COMBUSTION BLOWER	OPERATING CONDITIONS OR PROBLEM DIAGNOSIS
ON	OFF	ON	RUNNING	CHECK DISCHARGE AND/OR RESET SENSORS AND SETPOINT CALIBRATION
OFF	EITHER	ON	EITHER	FAULTY G-TRAC

Rapid Cycling of SA Contacts on G-TRAC Connected to BMS Reset

If a problem exists with the supply air fan rapid cycling during the first start up of the day and the G-TRAC is connected to a BMS system, there can be some interference. During the off cycle the warm air in the space may vent back to the unit keeping the discharge air sensor warmer than the internal set-point (*EG: set at 65°F*). When the unit is turned on in the morning, the BMS reset would be at zero VDC or 4 Ma at “+ and –” on the G-TRAC terminals. It is therefore demanding a 65°F air discharge temperature. As the temperature in the discharge plenum was warmer than 65°F, the G-TRAC would not call for heat, the fan will start in 34 seconds.

As soon as the fan starts, a current transformer, (*supplied and installed by others*) to prove our fan is running, sends a signal to the BMS panel. This proves that the unit is now on, which in turn allows the BMS to ramp its signal to 10VDC to the + and - terminals of the G-TRAC (*because the space temperature was cool from the unoccupied cycle the night before*).

This of course results in a call for heat, and cycles the fan off in order for the heat exchanger to warm up. Voltage to + and - would then go to 0 VDC, again resulting in no call for heat and the cycle will then repeat.

Note that some DDC or BMS panels **must** have a positive proof of fan operating before reset voltage is ramped up.

Installing a relay in parallel with the day/night terminal can rectify this problem. Use a VTM time delay and the DPDT relay contacts (*such as a Honeywell R8222*). This will lock out the BMS signal for minimum of 3 minutes. The 3 minutes is required to give the G-TRAC an opportunity to get into its normal operating mode.

G-TRAC not responding to BMS signal

Refer to the section on BMS above and Section X.

Flame Failure Lockouts

The G-TRAC does not have direct control of the flame supervision. That is usually the task of a Fireye M Series II Flame Supervision Relay. For most problems refer to the Fireye (*or other flame supervision device*) instructions. The following are a couple of items not covered on their manual.


1. If the combustion air damper is open when the burner starts, it can blow out the pilot flame as it tries to light. Ensure that the spring used to close the damper is operating correctly. The spring is usually found behind the gas valve and is attached to the gas valves damper linkage. (*A few units do not have a spring, they have a counter-weight*).
2. A very quick interruption of the power can cause a flame failure. The length of time of power failure is less than ½ second but longer than 1/1000 of a second.
3. A situation that allows for a flame to continue to burn after a heat call is complete, and if that flame is impinging on the flame rod, can lead to a flame failure if another heat call is made while the flame signal still exists. We call this a residual flame and it is possible due to the quantity of gas in the main manifold

after the main shut off valve still flowing due to its pressure and airflow patterns. Possible solutions to stop flame failures due to residual flame are:

- A. Slightly increase the quantity of low fire air to the burner to blow out the residual flame.
- B. Reduce or eliminate the flame around the flame rod by removing the source of the fuel. It is possible the fuel source is the nozzle located at 3 o'clock on the diffuser plate. Try to temporarily block this nozzle and note the results.
- C. Place a time delay relay into the FR flame relay circuit to not allow the flame relay to pull in until the residual flame has burnt out. (*Usually 30-60 seconds*).
- D. Cracked spark and flame rods.
- E. Proper positioning of the spark rod in relation to the pilot orifice and the depth of the pilot stub past the burner retention plate is very important (*see sketch below*).
- F. A poor ground path can contribute to flame failure problems. If this is suspected a ground wire can be screwed onto the retention plate and then connected to ground screen marked on the Fireye sub-base.

“B” and “C” BURNER ELECTRODE DETAIL

All Gas Ignition Electrode Require \square Gap for Sparking.



XIV. CHANGING A G-TRAC IN THE FIELD

TO SET PRE-PURGE TIME DELAY

Pre-purge time delay is set by cutting the pre-purge jumpers on the back of the G-TRAC board. This is best to do before installing a new board. Cut the same jumpers as were cut on the old board or contact the factory (*after getting unit serial number*) for correct jumper information. Pre-purge time is determined by the size of the heat exchanger and the time required to vent it.

The number in the brackets is the jumper wire setting. (*0 = cut; 1 = uncut*). The first digit refers to PP1, second to PP2, etc. Time is in MIN: SEC

Combustion Set Up

When measuring combustion, ensure probe of analyzer inserts fully in to the **flue connection to the heat exchanger**. Measuring at the flue outlet may be a diluted reading due to air mixing into the flue.

High Fire Combustion Set Up


Turn unit off. Remove wires at RBW terminals on (V9055) gas valve. Connect Q209 pot to gas valve. Turn unit back on. After unit lights off adjust Q209 to maximum fire. Ensure adequate inlet fuel pressure. Adjust high fire manifold pressure to that listed on the rating plate. Adjust combustion air inlet damper until high fire O₂ reading is between 3.5% and 4%. Mark high fire location on combustion air inlet damper.

Low Fire Combustion Set Up

Remove Q209 (*used in above step*). Attach G-TRAC wiring from terminals RBW to gas valve. Adjust discharge temperature pot or control to just bring heat light on. After unit lights off, adjust minimum position pot on gas valve so the burner has a complete flame around its ring. (*Unit could be clogged for low fire gas*). Adjust air inlet damper until low fire. O₂ reading is between 10.5 – 11.0%.

Mid-Fire Range Combustion Set Up

Reattach Q209 as instructed in high fire instructions above. After light off, ensure O₂ reading is close to graph below. Adjust Q209 stopping at 6 – 10 positions to check combustion products. Ideally it should follow as close to possible the graph below, however, due to gas valve/air damper curves it will not be a straight line. Ensure that at no time the O₂ falls below 2.5% or go above 11% O₂.



CHECK OUT FOR G-TRAC-1 NORMAL OPERATION

***Following flow chart covers many general operating/troubleshooting situations. If a more detailed manual is needed, contact the nearest EngA Factory.*

